



# TÜRK LOYDU

İKTİSADİ İŞLETMESİ

## TYPE APPROVAL CERTIFICATE

Certificate No: TO.DEB.12-0498-04

This Certificate consist of 2 Pages

This is to certify that the

CLASS A-60 DECK

With type designations

EGP/A 60

Manufactured by

ENSAR GEMİ VE YAN SANAYİ LİMİTED ŞİRKETİ  
İSTANBUL / TURKEY

Is found to comply with

The Rules of Türk Loydu and International Convention for the Safety of Life at Sea, 1974  
Including Amendments

**Application** : Approved for use as a fire retarding floor of class A-60.  
**Design** : ENSAR GEMİ VE YAN SANAYİ LİMİTED ŞİRKETİ  
**Sizes** : Maximum size of deck panel : 600 x 1000 x 62 mm (hxwxt)  
**Address of Manufacturer** : İstasyon Mah. Hatboyu Cad. No:55  
Tuzla- İstanbul – TURKEY

**Place and date**  
İSTANBUL 03.05.2012

**Subject to the conditions referred to 2<sup>nd</sup> page  
this certificate is valid until 02.05.2017**

**İ.İlker KARPUZ**  
Head Of Marine Division

**Akif Bülent HOLOSORLU**  
Surveyor

